



CHRISTINE D. ANINZO

Procurement Officer/Program Specialist

Christine.Aninzo@NMJudiciary.gov

October 28, 2025

ADDENDUM NO. 3: RESPONSE TO REQUEST FOR INFORMATION

RFP-2026-JUD-3/VSS BID NO. 42600006

**“KOTTEN TINIAN SECURITY CAMERA EQUIPMENT
AND INSTALLATION FOR THE NMI JUDICIARY”**

To Prospective Proposers:

This is Addendum No. 3 to RFP-2026-JUD-3/VSS BID NO. 42600006, “Kotten Tinian Security Camera Equipment and Installation for the NMI Judiciary” (“RFP”). Included in this Addendum, and attached hereto, is the following:

1. Response to Request for Information (October 22, 2025).

Thank you for your interest.

Sincerely,

CHRISTINE D. ANINZO

Procurement Officer

END OF ADDENDUM NO. 3.

NOTE TO ALL PROSPECTIVE PROPOSERS:

Please acknowledge receipt of this addendum via email to Procurement@NMJudiciary.gov. Prospective proposers must complete and include this addendum in the proposal submission.

Acknowledged by:

Company Name

First and Last Name

Title

Signature

Date



The
JUDICIARY
NORTHERN MARIANA ISLANDS

OFFICE OF PROCUREMENT

P.O. Box 502165 · Saipan, MP 96950
Guma' Hustisia · Susupe
Tel: (670) 236-9791 • Fax: (670) 236-9702

CHRISTINE D. ANINZO
Procurement Officer/Program Specialist
Christine.Aninzo@NMIJudiciary.gov

RESPONSE TO REQUEST FOR INFORMATION¹
RFP-2026-JUD-3/VSS BID NO. 42600006
“KOTTEN TINIAN SECURITY CAMERA EQUIPMENT
AND INSTALLATION FOR THE NMI JUDICIARY”
OCTOBER 28, 2025

1. **Response to #2 if the testers to be used must have current factory certification. In order to meet TIA/EIA 568 standards. A test analyzer must be calibrated to meet TIA/EIA standards, as the standards require that all test equipment be calibrated according to the manufacturer's recommendations before performing tests. Calibration is necessary to establish a baseline for accurate measurements and to ensure the installed cabling link meets the specified performance requirements, please confirm.**

Answer (“A”): Due to the scale of this project, the minimum requirement is for the use of a certified test analyzer for testing. Self-calibration of the certified test analyzer will suffice. Proposers are not restricted from presenting a current factory certification for the testing.

2. **Response to #3 does not require a Certified Network Technician. If the bidders are required to submit a “Signed Certified Cable Test Report”, wouldn’t the government want the technician who did the testing to be certified in the network infrastructure to meet TIA/EIA-568 standards, please confirm.**

(A): Due to the scale of this project, the minimum requirement is to provide an electronic test report for each cable run using a certified cable analyzer, with results passing applicable standards. Proposers are not restricted from presenting a certification for network technician.

¹ The request for information questionnaires was provided by prospective proposer(s). The Judiciary retained the exact language from the questionnaires without modifying its grammar or spelling.