

CHRISTINE D. ANINZO
Procurement Officer/Program Specialist
Christine.Aninzo@NMJJudiciary.gov

October 21, 2025

ADDENDUM NO. 1: RESPONSE TO REQUEST FOR INFORMATION
RFP-2026-JUD-3/VSS BID NO. 42600006
“KOTTEN TINIAN SECURITY CAMERA EQUIPMENT
AND INSTALLATION FOR THE NMI JUDICIARY”

To Prospective Proposers:

This is Addendum No. 1 to RFP-2026-JUD-3/VSS Bid No. 42600006, “Kotten Tinian Security Camera Equipment and Installation for the NMI Judiciary” (“RFP”). Included in this Addendum, and attached hereto, is the following:

1. Response to Request for Information (October 17, 2025); and
2. Response to Request for Information (October 17, 2025).

Thank you for your interest.

Sincerely,

 Digitally signed by
CHRISTINE ANINZO
Date: 2025.10.21
10:53:39 +10'00'

CHRISTINE D. ANINZO
Procurement Officer

END OF ADDENDUM NO. 1.

NOTE TO ALL PROSPECTIVE PROPOSERS:

Please acknowledge receipt of this addendum via email to Procurement@NMJJudiciary.gov. Prospective proposers must complete and include this addendum in the proposal submission.

Acknowledged by:

Company Name

First and Last Name

Title

Signature

Date



CHRISTINE D. ANINZO
Procurement Officer/Program Specialist
Christine.Aninzo@NMIJudiciary.gov

RESPONSE TO REQUEST FOR INFORMATION¹
RFP-2026-JUD-3/VSS BID NO. 42600006
“KOTTEN TINIAN SECURITY CAMERA EQUIPMENT
AND INSTALLATION FOR THE NMI JUDICIARY”
OCTOBER 21, 2025

1. Copy of site layout in CAD and PDF format

Answer (“A”): The Judiciary does not have a site layout in Computer-Aided Design (CAD) format. A Portable Document Format (PDF) detailing camera replacement is provided in Appendix A.

2. Clarification, if the testers to be used must have current factory certification.

A: The certified cable analyzer does not need to have a current factory certification, but the model used must meet TIA/EIA-568 standards.

3. Clarification, if the technician must have current network certification to test and certify the cables.

A: The RFP does not require a technician with current network certification to test and certify the cables, but the electronic test reports for cable testing must provide passing results based on TIA/EIA-568 standards through a certified cable analyzer.

4. May I kindly request a copy of the as-built plan for Kotten Tinian?

A: The Judiciary does not have a current as-built plan. A PDF detailing camera replacements and new installations is provided in Appendix A.

¹ The request for information questionnaires was provided by prospective proposer(s). The Judiciary retained the exact language from the questionnaires without modifying its grammar or spelling.